

City Of Heppner Fire

City of Heppner

Morr_fir01A

Building Type Fire - City	County Morrow	
Street 197 NW Willow St		
City Heppner	State OR	Zip 97836
Latitude 45.35477	Longitude 119.55455	
Tracking Code RVS in 2006	Inspection Date 7/25/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	3.6	0	0	0	0	0	0	0	3.6
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

City Of Heppner Fire

Final RVS Score

Final Type	Final Score
RM1	3.6

FEMA-154 Collapse Potential

Low (<1%)



Oregon Geology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

City Of Heppner Fire

Morr_fir01A

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
		1960	1970
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
5140	1	No	No
Plan Irregularities		Vertical Irregularities	
None		None	
None		None	
None		None	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	
			
W	Primary Structural Type	E	Primary Structural Type



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries