

Ione RFPD

Morr_fir03A

Ione RFPD

Building Type		County	
Fire - RFPD		Morrow	
Street			
160 W Main St.			
City	State	Zip	
Ione	OR	97843	
Latitude	Longitude		
45.50114	119.82628		
Tracking Code	Inspection Date		
RVS in 2006	7/25/2006		



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	S3	3.8	0	-0.5	0	0	-0.6	0	0	2.7
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Ione RFPD

Final RVS Score

Final Type

Final Score

S3

2.7

FEMA-154 Collapse Potential

Low (<1%)



Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
			1980
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	1	No	No

Plan Irregularities	Vertical Irregularities
Torsion: Eccentric Stiffness	None
None	None
None	None

Falling Hazards	Poor Conditions
None	None
None	None
None	None



SE General Site