

Riverside Junior/Senior High School

Morr_sch01A

Morrow SD 1

Building Type	County	
School	Morrow	
Street		
210 Boardman Ave		
City	State	Zip
Boardman	OR	97818
Latitude	Longitude	
45.84151	119.6977	
Tracking Code	Inspection Date	
RVS in 2006	7/25/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C2	3.6	-2	-0.5	0	1.6	0	-1.2	0	1.5
Secondary	RM1	3.6	-2	-0.5	0	0	0	-1.2	0	-0.1
Tertiary		0	0	0	0	0	0	0	0	0

Riverside Junior/Senior High School

Final RVS Score

Final Type	Final Score
RM1	-0.1

FEMA-154 Collapse Potential

Very High (100%)



OregonGeology

Riverside Junior/Senior High School

Morr_sch01A

Enrollment 455	Year Built (Field Verified) 1968	Year Built (Alt. Source) 1968	Est. Decade Built 1990
Total Area (square ft) 74273	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities Reentrant Corners:Other (Adjacent Build/Entity) None None		Vertical Irregularities Steps in Elevation View: Single Change Steps in Elevation View: Single Change (Adjacent Building/Entity) None	
Falling Hazards None None None		Poor Conditions None None None	
			
SE Vertical Irregularity Primary		SE Plan Irregularity Primary	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Riverside Junior/Senior High School

Morr_sch01B

Morrow SD 1

Building Type	County	
School	Morrow	
Street		
210 Boardman Ave.		
City	State	Zip
Boardman	OR	97818
Latitude	Longitude	
45.84175	119.69703	
Tracking Code	Inspection Date	
RVS in 2006	7/25/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	3.6	-2	-0.5	0	0	0	-1.2	0	-0.1
Secondary	C2	3.6	-2	-0.5	0	0	0	-1.2	0	-0.1
Tertiary		0	0	0	0	0	0	0	0	0


Riverside Junior/Senior High School

Final RVS Score

Final Type	Final Score
RM1	-0.1

FEMA-154 Collapse Potential

Very High (100%)



OregonGeology

Riverside Junior/Senior High School

Morr_sch01B

Enrollment 455	Year Built (Field Verified) 1968	Year Built (Alt. Source) 1968	Est. Decade Built 1970
Total Area (square ft) 74273	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities Reentrant Corners:Other (Adjacent Build/Entity) None None		Vertical Irregularities Steps in Elevation View: Single Change (Adjacent Building/Entity) Building On Hill or Sloped Site None	
Falling Hazards None None None		Poor Conditions None None None	
			
NE Vertical Irregularity Secondary			



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Riverside Junior/Senior High School

Morr_sch01C

Morrow SD 1

Building Type	County	
School	Morrow	
Street		
210 Boardman Ave		
City	State	Zip
Boardman	OR	97818
Latitude	Longitude	
45.84191	119.69792	
Tracking Code	Inspection Date	
RVS in 2006	7/25/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W1	5.2	0	-0.5	0	1.6	0	-0.6	0	5.7
Secondary	RM1	3.6	0	-0.5	0	0	0	-1.2	0	1.9
Tertiary	C2	3.6	0	-0.5	0	0	0	-1.2	0	1.9

Riverside Junior/Senior High School

Final RVS Score

Final Type	Final Score
RM1	1.9

FEMA-154 Collapse Potential

Moderate (>1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Riverside Junior/Senior High School

Morr_sch01C

Enrollment 455	Year Built (Field Verified) 1968	Year Built (Alt. Source) 1968	Est. Decade Built 1980
Total Area (square ft) 74273	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities Reentrant Corners: Other None None		Vertical Irregularities None None None	
Falling Hazards None None None		Poor Conditions None None None	
			
NW Plan Irregularity Primary			

Riverside Junior/Senior High School

Morr_sch01D

Morrow SD 1

Building Type	County	
School	Morrow	
Street		
210 Boardman Ave		
City	State	Zip
Boardman	OR	97818
Latitude	Longitude	
45.84226	119.69648	
Tracking Code	Inspection Date	
RVS in 2006	7/25/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	3.6	0	-0.5	0	0	0	-1.2	0	1.9
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0


Riverside Junior/Senior High School

Final RVS Score

Final Type	Final Score
RM1	1.9

FEMA-154 Collapse Potential

Moderate (>1%)



OregonGeology

Riverside Junior/Senior High School

Morr_sch01D

Enrollment 455	Year Built (Field Verified) 1968	Year Built (Alt. Source) 1968	Est. Decade Built 1960
Total Area (square ft) 74273	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities Reentrant Corners: L Shaped None None		Vertical Irregularities None None None	
Falling Hazards None None None		Poor Conditions None None None	
 S Plan Irregularity Primary			



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries