

Heppner Junior/Senior High School

Morr_sch09A

Morrow SD 1

Building Type	County	
School	Morrow	
Street		
710 NW Morgan St.		
City	State	Zip
Heppner	OR	97836
Latitude	Longitude	
45.36158	119.56474	
Tracking Code	Inspection Date	
RVS in 2006	7/25/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	3.6	-2	-0.5	0	0	0	0	0	1.1
Secondary	C2	3.6	-2	-0.5	0	0	0	0	0	1.1
Tertiary	W2	4.8	-3	-0.5	0	0	0	0	0	1.3

Heppner Junior/Senior High School

Final RVS Score

Final Type	Final Score
RM1	1.1

FEMA-154 Collapse Potential

Moderate (>1%)



OregonGeology

Heppner Junior/Senior High School

Morr_sch09A

Enrollment 224	Year Built (Field Verified) 1963	Year Built (Alt. Source) 1963	Est. Decade Built 1960
Total Area (square ft) 65837	Number of Stories 2	Basement	Pounding Potential No
Plan Irregularities Reentrant Corners: Other None None		Vertical Irregularities Steps in Elevation View: Very Irregular Changes Building On Hill or Sloped Site None	
Falling Hazards None None None		Poor Conditions None None None	
 NW Plan Irregularity Primary		 W Other	
		 E Plan Irregularity Primary	

Heppner Junior/Senior High School

Morrow SD 1

Morr_sch09B

Building Type	County	
School	Morrow	
Street		
710 NW Morgan St.		
City	State	Zip
Heppner	OR	97836
Latitude	Longitude	
45.36062	119.56482	
Tracking Code	Inspection Date	
RVS in 2006	7/25/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	3.6	-2	0	0	0	0	0	0	1.6
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Heppner Junior/Senior High School

Final RVS Score

Final Type	Final Score
RM1	1.6

FEMA-154 Collapse Potential

Moderate (>1%)



OregonGeology

Heppner Junior/Senior High School

Morr_sch09B

Enrollment 224	Year Built (Field Verified) 1963	Year Built (Alt. Source) 1963	Est. Decade Built 1970
Total Area (square ft) 65837	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities None None None		Vertical Irregularities Building On Hill or Sloped Site None None	
Falling Hazards None None None		Poor Conditions None None None	