

Building Type	County		
Community_College	Multnomah		
Street			
1484 NW Civic Drive			
City	State	Zip	
Gresham	OR	97030	
Latitude	Longitude		
45.5166	122.39541		
Tracking Code	Inspection Date		
Miller 2004-05	7/20/2005		

Seismicity Zone: High

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C2	2.8	-1	-0.5	0	0	-0.4	0	0	0.9
Secondary	RM1	2.8	-1	-0.5	0	0	-0.4	0	0	0.9
Tertiary		0	0	0	0	0	0	0	0	0


Bruning Center for Allied Health

## Final RVS Score

Final Type	Final Score
C2	0.9

## FEMA-154 Collapse Potential

High (&gt;10%)



# Bruning Center for Allied Health

Mult\_coc02A

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
	1976	1976	1970
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
63054	3	Yes	No
Plan Irregularities		Vertical Irregularities	
Yes: Unknown		Yes: Unknown	
Falling Hazards		Poor Conditions	
None			
None			
None			