

Industrial Technology

Mult_coc03A

Mt Hood CC

Building Type Community_College	County Multnomah	
Street 26000 Se Stark St		
City Gresham	State OR	Zip 97030
Latitude 45.51596	Longitude 122.39488	
Tracking Code Miller 2004-05	Inspection Date 7/20/2005	

Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	2.8	-1	-0.5	0	0	0	0	0	1.3
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0


Industrial Technology

Final RVS Score

Final Type	Final Score
RM1	1.3

FEMA-154 Collapse Potential

Moderate (>1%)



Industrial Technology

Mult_coc03A

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
	1968	1968	1960
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
45748	1	No	No
Plan Irregularities		Vertical Irregularities	
None		None	
Falling Hazards		Poor Conditions	
None			
None			
None			