

Aquatic Center

Mult_coc04A

Mt Hood CC

Building Type Community_College	County Multnomah	
Street 26000 Se Stark St		
City Gresham	State OR	Zip 97030
Latitude 45.5111	Longitude 122.39838	
Tracking Code Miller 2004-05	Inspection Date 7/20/2005	

Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	PC1	2.6	0	-0.5	0	0	0	0	0	2.1
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0


Aquatic Center

Final RVS Score

Final Type	Final Score
PC1	2.1

FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Aquatic Center

Mult_coc04A

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
	1976	1976	1970
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
27500	1	No	No
Plan Irregularities		Vertical Irregularities	
Yes: Unknown		Yes: Unknown	
Falling Hazards		Poor Conditions	
None			
None			
None			



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries