

Gymnasium

Mult_coc05A

Mt Hood CC

Building Type Community_College	County Multnomah	
Street 26000 Se Stark St		
City Gresham	State OR	Zip 97030
Latitude 45.51206	Longitude 122.39581	
Tracking Code Miller 2004-05	Inspection Date 7/20/2005	

Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	PC1	2.6	0	-0.5	0	0	0	0	0	2.1
Secondary	RM1	2.8	-1	-0.5	0	0	0	0	0	1.3
Tertiary	C2	2.8	-1	-0.5	0	0	0	0	0	1.3


Gymnasium

Final RVS Score

Final Type	Final Score
RM1	1.3

FEMA-154 Collapse Potential

Moderate (>1%)



OregonGeology

Gymnasium

Mult_coc05A

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
	1968	1968	1960
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
55355		No	No
Plan Irregularities		Vertical Irregularities	
Yes: Unknown		Yes: Unknown	
Falling Hazards		Poor Conditions	
None			
None			
None			



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries