

Academic Center

Mult_coc06A

Mt Hood CC

Building Type		County	
Community_College		Multnomah	
Street			
26000 Se Stark St			
City	State	Zip	
Gresham	OR	97030	
Latitude		Longitude	
45.51553		122.396	
Tracking Code		Inspection Date	
Miller 2004-05		7/20/2005	

Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	S5	2	-1	-0.5	0	0	0	0	0	0.5
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Academic Center

Final RVS Score

Final Type


Final Score

S5

0.5

FEMA-154 Collapse Potential

High (>10%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
	1970	1970	1970
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
421365	3	Yes	No

Plan Irregularities	Vertical Irregularities
Yes: Unknown	Yes: Unknown

Falling Hazards	Poor Conditions
None	
None	
None	