

Child Development Center

Mult_coc09A

Mt Hood CC

Building Type		County	
Community_College		Multnomah	
Street			
26000 SE Stark St			
City	State	Zip	
Gresham	OR	97030	
Latitude		Longitude	
45.51677		122.3935	
Tracking Code		Inspection Date	
RVS in 2006		9/14/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	0	-0.5	0	0	0	0	0	3.3
Secondary	S3	3.2	0	0	0	0	0	0	0	3.2
Tertiary		0	0	0	0	0	0	0	0	0

Child Development Center

Final RVS Score

Final Type


Final Score

S3

3.2

FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Child Development Center

Mult_coc09A

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
			1970
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
		No	No

Plan Irregularities	Vertical Irregularities
Reentrant Corners: Other	None
None	None
None	None

Falling Hazards	Poor Conditions
None	None
None	None
None	None



S Building Name



SE General Site
Early childhood edu bldg too small to screen.



SE Plan Irregularity Primary



SW General Site
Head start bldg too small to screen -2800sqft



SW Plan Irregularity Primary