

Sylvania - Social Science and Technology

Mult_coc30A

Portland CC

Building Type	County	
Community_College	Multnomah	
Street		
12000 Sw 49th Ave		
City	State	Zip
Portland	OR	97219
Latitude	Longitude	
45.43699	122.73173	
Tracking Code	Inspection Date	
Miller 2004-05	8/31/2005	

Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C1	2.5	-1.5	-0.5	0	0	-0.4	0	0	0.1
Secondary	RM1	2.8	-1	-0.5	0	0	-0.4	0	0	0.9
Tertiary		0	0	0	0	0	0	0	0	0


Sylvania - Social Science and Technology

Final RVS Score

Final Type	Final Score
C1	0.1

FEMA-154 Collapse Potential

High (>10%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Sylvania - Social Science and Technology

Mult_coc30A

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
	1968	1968	1960
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
61899	2	No	No
Plan Irregularities		Vertical Irregularities	
None		None	
Falling Hazards		Poor Conditions	
None			
None			
None			