

Gresham Fire Station 72 Kane Road

City of Gresham

Mult_fir03A

Building Type	County
Fire - City	Multnomah
Street	
500 NE Kane	
City	State Zip
Gresham	OR 97030
Latitude	Longitude
45.50172	122.39944
Tracking Code	Inspection Date
RVS in 2006	7/5/2006



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	-2	0	0	0	0	0	0	1.8
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Gresham Fire Station 72 Kane Road

Final RVS Score

Final Type	Final Score
W2	1.8

FEMA-154 Collapse Potential

Moderate (>1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Gresham Fire Station 72 Kane Road

Mult_fir03A

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
		1974	1970
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
306662	1	No	No
Plan Irregularities		Vertical Irregularities	
Lateral-Force-Resistance in One Direction Only		Steps in Elevation View: Single Change	
None		None	
None		None	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	
			
SW Elevation View		NW Vertical Irregularity Primary	
		NE Elevation View	
		E Elevation View	