

City of Portland

Building Type Fire - City	County Multnomah	
Street 8720 SW 30th Avenue		
City Portland	State OR	Zip 97219
Latitude 45.46193	Longitude 122.70746	
Tracking Code RVS in 2006	Inspection Date 9/21/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	2.8	-1	-0.5	0	0	-0.4	0	0	0.9
Secondary	W1	4.4	-2.5	-0.5	0	0	0	0	0	1.4
Tertiary		0	0	0	0	0	0	0	0	0

Portland F & R - Station 18
Multnomah Village

Final RVS Score

Final Type	Final Score
RM1	0.9

FEMA-154 Collapse Potential

High (>10%)

No
Planview
Available



Oregon Geology

Portland F & R - Station 18 Multnomah Village

Mult_fir13A

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
	1960	1960	1960
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
5758	1	No	No
Plan Irregularities		Vertical Irregularities	
Reentrant Corners: Other		Steps in Elevation View: Single Change	
Torsion: Eccentric Stiffness		None	
None		None	
Falling Hazards		Poor Conditions	
Unreinforced Chimneys		None	
Other: Brick Veneer		None	
None		None	
			
SW	Vertical Irregularity Primary	W	Building Name
			
NW	Falling Hazard	S	Field Verified Year Built
			
SE	Plan Irregularity Secondary	SE	Primary Structural Type BRICK WALLS



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries