

Multnomah County RFPD 14 Corbett Station #62 Gar

Mult_fir38A

Multnomah County RFPD 14 Aims Station #63

Building Type Fire - RFPD	County Multnomah	
Street 36930 E HISTORIC COLUMBIA RIVER HWY		
City Corbett	State OR	Zip 97019
Latitude 45.53179	Longitude 122.28377	
Tracking Code RVS in 2006	Inspection Date 7/5/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	S3	3.2	0	-0.5	0	0	-0.4	0	0	2.3
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Multnomah County RFPD 14
Corbett Station #62 Garage

Final RVS Score

Final Type	Final Score
S3	2.3

FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Multnomah County RFPD 14 Corbett Station #62 Garage

Mult_fir38A

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
		1968	1970
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
6100	1	No	No
Plan Irregularities		Vertical Irregularities	
Torsion: Eccentric Stiffness		None	
None		None	
None		None	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	
			
E	Building Name	SW	Elevation View



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Multnomah County RFPD 14 Corbett Station #62 Offi

Mult_fir38B

Multnomah County RFPD 14 Aims Station #63

Building Type	County	
Fire - RFPD	Multnomah	
Street		
36930 E HISTORIC COLUMBIA RIVER HWY		
City	State	Zip
Corbett	OR	97019
Latitude	Longitude	
45.53179	122.28349	
Tracking Code	Inspection Date	
RVS in 2006	7/5/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	S3	3.2	0	0	0	0	-0.4	0	0	2.8
Secondary	C2	2.8	0	0	0	0	-0.4	0	0	2.4
Tertiary		0	0	0	0	0	0	0	0	0

Multnomah County RFPD 14
Corbett Station #62 Office

Final RVS Score

Final Type	Final Score
C2	2.4

FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
		1968	1970
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
6100	1	No	No
Plan Irregularities		Vertical Irregularities	
None		None	
None		None	
None		None	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	
			
NE Elevation View			

