

# Multnomah County RFPD 14 Aims Station #63

Mult\_fir46A

Multnomah County RFPD 14 Aims Station #63

Building Type	County	
Fire - RFPD	Multnomah	
Street		
40750 Gordon Creek Rd		
City	State	Zip
Corbett	OR	97019
Latitude	Longitude	
45.46947	122.24444	
Tracking Code	Inspection Date	
RVS in 2006	7/5/2006	



Seismicity Zone: Moderate

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	S3	3.8	0	0	0	0	-0.6	0	0	3.2
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Multnomah County RFPD 14 Aims Station #63

## Final RVS Score

Final Type	Final Score
S3	3.2

## FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

# Multnomah County RFPD 14 Aims Station #63

Mult\_fir46A

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
			1990
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	1	No	No
Plan Irregularities		Vertical Irregularities	
None		None	
None		None	
None		None	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	
			
SE Elevation View		NW Elevation View	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries