

Multnomah County Sheriff's Office

Mult_pol13A

Multnomah County

| | | |
|--------------------|-----------------|-------|
| Building Type | County | |
| Police - County | Multnomah | |
| Street | | |
| 12240 NE Glisan St | | |
| City | State | Zip |
| Portland | OR | 97230 |
| Latitude | Longitude | |
| 45.52589 | 122.53684 | |
| Tracking Code | Inspection Date | |
| SER & RVS2006 | 7/13/2006 | |



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

| | Type | Basic Score | Vert Irreg | Plan Irreg | Pre-Code | Post-Bench | Soil C | Soil D | Soil E | RVS Score |
|-----------|------|-------------|------------|------------|----------|------------|--------|--------|--------|-----------|
| Primary | C2 | 2.8 | -1 | -0.5 | 0 | 0 | -0.4 | 0 | 0 | 0.9 |
| Secondary | RM1 | 2.8 | -1 | -0.5 | 0 | 0 | -0.4 | 0 | 0 | 0.9 |
| Tertiary | | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |

Multnomah County Sheriff's Office

Final RVS Score

| Final Type | Final Score |
|------------|-------------|
| C2 | 0.9 |

FEMA-154 Collapse Potential

High (>10%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Multnomah County Sheriff's Office

Mult_pol13A

| | | | |
|---|-----------------------------|---|--------------------|
| Enrollment | Year Built (Field Verified) | Year Built (Alt. Source) | Est. Decade Built |
| | 1956 | 1956 | 1950 |
| Total Area (square ft) | Number of Stories | Basement | Pounding Potential |
| | 2 | Yes | No |
| Plan Irregularities | | Vertical Irregularities | |
| Reentrant Corners: Other | | Steps in Elevation View: 2 to 3 Changes | |
| None | | Short Columns | |
| None | | None | |
| Falling Hazards | | Poor Conditions | |
| Other: Ornamental Hazard Over Exit | | None | |
| None | | None | |
| None | | None | |
|  | |  | |
| N Elevation View | | N Falling Hazard | |
|  | |  | |
| SW Plan Irregularity Primary | | SW Vertical Irregularity Secondary | |
|  | |  | |
| NE Elevation View | | N Field Verified Year Built | |



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Multnomah County Fleet Service

Mult_pol13B

Multnomah County

| | | |
|----------------------------------|------------------------------|--------------|
| Building Type Police - County | County Multnomah | |
| Street 12338 NE Glisan St | | |
| City Portland | State OR | Zip 97230 |
| Latitude 45.52597 | Longitude 122.53594 | |
| Tracking Code SER & RVS2006 | Inspection Date 7/13/2006 | |



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

| | Type | Basic Score | Vert Irreg | Plan Irreg | Pre-Code | Post-Bench | Soil C | Soil D | Soil E | RVS Score |
|-----------|------|-------------|------------|------------|----------|------------|--------|--------|--------|-----------|
| Primary | RM1 | 2.8 | -1 | -0.5 | 0 | 0 | -0.4 | 0 | 0 | 0.9 |
| Secondary | | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Tertiary | | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |

Multnomah County Fleet Service

Final RVS Score

| Final Type | Final Score |
|------------|-------------|
| RM1 | 0.9 |

FEMA-154 Collapse Potential

High (>10%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Multnomah County Fleet Service

Mult_pol13B

| | | | |
|--|-----------------------------|--|--------------------|
| Enrollment | Year Built (Field Verified) | Year Built (Alt. Source) | Est. Decade Built |
| | | 1956 | 1950 |
| Total Area (square ft) | Number of Stories | Basement | Pounding Potential |
| | 1 | No | No |
| Plan Irregularities | | Vertical Irregularities | |
| Torsion: Eccentric Stiffness | | Steps in Elevation View: Single Change | |
| None | | None | |
| None | | None | |
| Falling Hazards | | Poor Conditions | |
| Other: Ornamental Hazard Over Exit | | None | |
| None | | None | |
| None | | None | |
|  | | | |
| NE Elevation View | | | |