

Alameda Elementary School

Mult_sch01A

Portland SD 1J

Building Type		County	
School		Multnomah	
Street			
2732 Ne Fremont St			
City	State	Zip	
Portland	OR	97212	
Latitude		Longitude	
45.54791		122.63725	
Tracking Code		Inspection Date	
Structural Engineering Report		9/15/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	-2	-0.5	-1	0	-0.4	0	0	-0.1
Secondary										
Tertiary										0

Alameda Elementary School

Final RVS Score

Final Type

Final Score

W2

-0.1

FEMA-154 Collapse Potential

Very High (100%)

**No
Planview
Available**



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
669		1921	
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
64957	1	No	No

Plan Irregularities	Vertical Irregularities

Falling Hazards	Poor Conditions

