

Building Type	County	
School	Multnomah	
Street		
5109 Se 66th Ave		
City	State	Zip
Portland	OR	97206
Latitude	Longitude	
45.48606	122.59615	
Tracking Code	Inspection Date	
Structural Engineering Report		
9/15/2006		



Seismicity Zone: High

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C2	2.8	-1	-0.5	-1	0	-0.4	0	0	-0.1
Secondary										
Tertiary										0

## Arleta Elementary School

## Final RVS Score

Final Type	Final Score
C2	-0.1

## FEMA-154 Collapse Potential

Very High (100%)

No  
Planview  
Available



# Arleta Elementary School

Mult\_sch02A

Enrollment 313	Year Built (Field Verified) 1929	Year Built (Alt. Source) 1929	Est. Decade Built
Total Area (square ft) 76489	Number of Stories 2	Basement	Pounding Potential No
Plan Irregularities		Vertical Irregularities	
Falling Hazards		Poor Conditions	