

Building Type	County	
School	Multnomah	
Street		
5601 N Yale St		
City	State	Zip
Portland	OR	97203
Latitude	Longitude	
45.57866	122.72968	
Tracking Code	Inspection Date	
Already Retrofitted	9/15/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	-2	-0.5	0	0	0	-0.8	0	0.5
Secondary										
Tertiary										0

Astor Elementary School

Final RVS Score

Final Type	Final Score
W2	0.5

FEMA-154 Collapse Potential

Moderate (>1%)

No
Planview
Available



Oregon Geology

Astor Elementary School

Mult_sch03A

Enrollment 279	Year Built (Field Verified) 1949	Year Built (Alt. Source) 1949	Est. Decade Built
Total Area (square ft) 47360	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities		Vertical Irregularities	
Falling Hazards		Poor Conditions	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries