

Building Type	County	
School	Multnomah	
Street		
5800 SE Division St		
City	State	Zip
Portland	OR	97206
Latitude	Longitude	
45.50487	122.60468	
Tracking Code	Inspection Date	
Already Retrofitted	9/15/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	-2	-0.5	0	0	0	-0.8	0	0.5
Secondary										
Tertiary										0

Atkinson Elementary School

Final RVS Score

Final Type

Final Score

W2

0.5

FEMA-154 Collapse Potential

Moderate (>1%)

No Planview Available



Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
558		1953	
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
58057	1	No	No

Plan Irregularities	Vertical Irregularities

Falling Hazards	Poor Conditions