

Ball Elementary School

Portland SD 1J

Mult_sch05A

Building Type	County
School	Multnomah
Street	
4221 N Willis Blvd	
City	State Zip
Portland	OR 97203
Latitude	Longitude
45.5844	122.71075
Tracking Code	Inspection Date
Already Retrofitted	9/15/2006



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	-2	-0.5	0	0	-0.4	0	0	0.9
Secondary										
Tertiary										0

Ball Elementary School

Final RVS Score

Final Type	Final Score
W2	0.9

FEMA-154 Collapse Potential

Moderate (>1%)

No
Planview
Available



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Ball Elementary School

Mult_sch05A

Enrollment 271	Year Built (Field Verified) 1948	Year Built (Alt. Source) 1948	Est. Decade Built
Total Area (square ft) 22797	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities		Vertical Irregularities	
Falling Hazards		Poor Conditions	