

Building Type	County	
School	Multnomah	
Street		
1710 N Humboldt St		
City	State	Zip
Portland	OR	97217
Latitude	Longitude	
45.55799	122.68546	
Tracking Code	Inspection Date	
Structural Engineering Report	9/15/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C2	2.8	-1	-0.5	-1	0	-0.4	0	0	-0.1
Secondary										
Tertiary										0

Beach Elementary School

Final RVS Score

Final Type

Final Score

C2

-0.1

FEMA-154 Collapse Potential

Very High (100%)

No Planview Available



Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
414		1928	
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
70404	3	No	No

Plan Irregularities	Vertical Irregularities

Falling Hazards	Poor Conditions