

Building Type	County	
School	Multnomah	
Street		
2231 N Flint		
City	State	Zip
Portland	OR	97227
Latitude	Longitude	
45.53903	122.66923	
Tracking Code	Inspection Date	
Structural Engineering Report	9/15/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C2	2.8	-1	-0.5	0	0	-0.4	0	0	0.9
Secondary										
Tertiary										0

Tubman Middle School

Final RVS Score

Final Type	Final Score
C2	0.9

FEMA-154 Collapse Potential

High (>10%)

Tubman Middle School

Mult_sch109A

Enrollment 270	Year Built (Field Verified) 1954	Year Built (Alt. Source) 1954	Est. Decade Built
Total Area (square ft) 94775	Number of Stories 2	Basement	Pounding Potential No
Plan Irregularities		Vertical Irregularities	
<input type="text"/>		<input type="text"/>	
<input type="text"/>		<input type="text"/>	
<input type="text"/>		<input type="text"/>	
Falling Hazards		Poor Conditions	
<input type="text"/>		<input type="text"/>	
<input type="text"/>		<input type="text"/>	
<input type="text"/>		<input type="text"/>	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries