

# Vestal Elementary School

Mult\_sch111A

Portland SD 1J

Building Type		County	
School		Multnomah	
Street			
161 Ne 82nd Ave			
City	State	Zip	
Portland	OR	97220	
Latitude	Longitude		
45.52455	122.57962		
Tracking Code	Inspection Date		
Already Retrofitted	9/15/2006		



Seismicity Zone: High

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C2	2.8	-1	-0.5	-1	0	-0.4	0	0	-0.1
Secondary										
Tertiary										0

Vestal Elementary School

## Final RVS Score

Final Type

Final Score

C2

-0.1

FEMA-154 Collapse Potential

Moderate (>1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
294		1929	
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
66388	2	No	No

Plan Irregularities	Vertical Irregularities

Falling Hazards	Poor Conditions