

# Woodstock Elementary School

Portland SD 1J

Mult\_sch117A

Building Type	County	
School	Multnomah	
Street		
5601 Se 50Th Ave		
City	State	Zip
Portland	OR	97206
Latitude	Longitude	
45.48203	122.61203	
Tracking Code	Inspection Date	
Already Retrofitted	9/15/2006	



Seismicity Zone: High

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	-2	-0.5	-1	0	-0.4	0	0	-0.1
Secondary										
Tertiary										0

Woodstock Elementary School

## Final RVS Score

Final Type	Final Score
W2	-0.1

## FEMA-154 Collapse Potential

Moderate (>1%)

# Woodstock Elementary School

Mult\_sch117A

Enrollment 337	Year Built (Field Verified) 1910	Year Built (Alt. Source) 1910	Est. Decade Built
Total Area (square ft) 69135	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities		Vertical Irregularities	
Falling Hazards		Poor Conditions	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries