

Grant High School

Portland SD 1J

Mult_sch120A

Building Type	County		
School	Multnomah		
Street			
2245 Ne 36th Ave			
City	State	Zip	
Portland	OR	97212	
Latitude	Longitude		
45.53906	122.62674		
Tracking Code	Inspection Date		
Already Retrofitted	9/15/2006		



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	URM	1.8	-1	-0.5	-0.2	0	-0.4	0	0	-0.3
Secondary										
Tertiary										0

Grant High School

Final RVS Score

Final Type

Final Score

URM

-0.3

FEMA-154 Collapse Potential

Moderate (>1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
1816		1923	
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
275173	2	No	No

Plan Irregularities	Vertical Irregularities

Falling Hazards	Poor Conditions