

Building Type School	County Multnomah	
Street 2735 Ne 82nd Ave		
City Portland	State OR	Zip 97220
Latitude 45.54195	Longitude 122.58087	
Tracking Code Already Retrofitted	Inspection Date 9/15/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C2	2.8	-1	-0.5	0	0	-0.4	0	0	0.9
Secondary										
Tertiary										0

Madison High School

Final RVS Score

Final Type	Final Score
C2	0.9

FEMA-154 Collapse Potential

Moderate (>1%)

Madison High School

Mult_sch122A

Enrollment 981	Year Built (Field Verified) 1955	Year Built (Alt. Source) 1955	Est. Decade Built
Total Area (square ft) 370122	Number of Stories 3	Basement	Pounding Potential No
Plan Irregularities		Vertical Irregularities	
Falling Hazards		Poor Conditions	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries