

Building Type	County	
School	Multnomah	
Street		
2033 Nw Glisan St		
City	State	Zip
Portland	OR	97209
Latitude	Longitude	
45.52672	122.6932	
Tracking Code	Inspection Date	
Already Retrofitted	9/15/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card										
	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C2	2.8	-1	-0.5	-1	0	-0.4	0	0	-0.1
Secondary										
Tertiary										0

Metropolitan Learning Center

Final RVS Score

Final Type	Final Score
C2	-0.1

FEMA-154 Collapse Potential

Moderate (>1%)

Metropolitan Learning Center

Mult_sch123A

Enrollment 447	Year Built (Field Verified) 1914	Year Built (Alt. Source) 1914	Est. Decade Built
Total Area (square ft) 77050	Number of Stories 3	Basement	Pounding Potential No
Plan Irregularities		Vertical Irregularities	
Falling Hazards		Poor Conditions	