

Hollydale Elementary School

Gresham-Barlow SD 10J

Mult_sch132A

Building Type	County	
School	Multnomah	
Street		
505 SW Birdsdale Ave		
City	State	Zip
Gresham	OR	97080
Latitude	Longitude	
45.49271	122.45466	
Tracking Code	Inspection Date	
RVS in 2006	7/20/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C2	2.8	-1	-0.5	0	0	0	0	0	1.3
Secondary	S2	3	-1.5	-0.5	0	0	0	0	0	1
Tertiary	RM1	2.8	-1	-0.5	0	0	0	0	0	1.3

Hollydale Elementary School

Final RVS Score

Final Type	Final Score
S2	1

FEMA-154 Collapse Potential

High (>10%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Hollydale Elementary School

Mult_sch132A

Enrollment 438	Year Built (Field Verified) 1979	Year Built (Alt. Source) 1970	Est. Decade Built 1970
Total Area (square ft) 57113	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities Reentrant Corners: Other None None		Vertical Irregularities Steps in Elevation View: Single Change None None	
Falling Hazards None None None		Poor Conditions None None None	
 E Elevation View		 E Other	
 N Elevation View		 S Plan Irregularity Primary	
 S Secondary Structural Type		 SE Elevation View	
 SW Elevation View			



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Hollydale Elementary School

Mult_sch132A



W General Site



W General Site