

Hartley Elementary School

Reynolds SD 7

Mult_sch141A

Building Type	County
School	Multnomah
Street	
701 NE 185th Ave	
City	State Zip
Portland	OR 97230
Latitude	Longitude
45.52826	122.47228
Tracking Code	Inspection Date
RVS in 2006	7/17/2006



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	PC1	2.6	0	-0.5	0	0	-0.4	0	0	1.7
Secondary	C2	2.8	-1	-0.5	0	0	-0.4	0	0	0.9
Tertiary	W2	3.8	-2	-0.5	0	0	-0.4	0	0	0.9

Hartley Elementary School

Final RVS Score

Final Type	Final Score
C2	0.9

FEMA-154 Collapse Potential

High (>10%)




OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Hartley Elementary School

Mult_sch141A

Enrollment 401	Year Built (Field Verified) 1963	Year Built (Alt. Source) 1963	Est. Decade Built 1960
Total Area (square ft) 39650	Number of Stories 1	Basement	Pounding Potential Yes
Plan Irregularities Reentrant Corners: Other Reentrant Corners: Other (Adjacent Build/Entity) None		Vertical Irregularities Steps in Elevation View: 2 to 3 Changes Steps in Elevation View: 2 to 3 Changes (Adjacent Building/Entity) None	
Falling Hazards None None None		Poor Conditions None None None	
			
SE Elevation View	NE Elevation View	NE Primary Structural Type	
			
E Primary Structural Type DETAIL SHOWN ON PLAN	NW Elevation View	N Primary Structural Type	
			
W Tertiary Structural Type	W Plan Irregularity Primary	NE General Site	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries



NW Elevation View



Hartley Elementary School

Reynolds SD 7

Mult_sch141B

Building Type	County
School	Multnomah
Street	
701 NE 185th Ave	
City	State Zip
Portland	OR 97230
Latitude	Longitude
45.52865	122.47207
Tracking Code	Inspection Date
RVS in 2006	7/17/2006



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	2.8	-1	-0.5	0	0	-0.4	0	0	0.9
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Hartley Elementary School

Final RVS Score

Final Type	Final Score
RM1	0.9

FEMA-154 Collapse Potential

High (>10%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Hartley Elementary School

Mult_sch141B

Enrollment 401	Year Built (Field Verified) 1963	Year Built (Alt. Source) 1963	Est. Decade Built 1990
Total Area (square ft) 39650	Number of Stories 1	Basement	Pounding Potential Yes
Plan Irregularities Reentrant Corners:Other (Adjacent Build/Entity) None None		Vertical Irregularities Steps in Elevation View: Single Change Steps in Elevation View: Single Change (Adjacent Building/Entity) None	
Falling Hazards None None None		Poor Conditions None None None	
 E Vertical Irregularity Primary		 NW Elevation View	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Hartley Elementary School

Reynolds SD 7

Mult_sch141C

Building Type	County
School	Multnomah
Street	
701 NE 185th Ave	
City	State Zip
Portland	OR 97230
Latitude	Longitude
45.52808	122.47215
Tracking Code	Inspection Date
RVS in 2006	7/17/2006



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	S2	3	-1.5	-0.5	0	0	-0.4	0	0	0.6
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Hartley Elementary School

Final RVS Score

Final Type	Final Score
S2	0.6

FEMA-154 Collapse Potential

High (>10%)



OregonGeology

Hartley Elementary School

Mult_sch141C

Enrollment 401	Year Built (Field Verified) 1963	Year Built (Alt. Source) 1963	Est. Decade Built 1990
Total Area (square ft) 39650	Number of Stories 1	Basement	Pounding Potential Yes
Plan Irregularities Reentrant Corners: Other Reentrant Corners: Other (Adjacent Build/Entity) None		Vertical Irregularities Steps in Elevation View: 2 to 3 Changes Steps in Elevation View: 2 to 3 Changes (Adjacent Building/Entity) None	
Falling Hazards None None None		Poor Conditions None None None	
 E Primary Structural Type			



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries