

Harold Oliver Intermediate Center

Centennial SD 28J

Mult_sch150A

Building Type		County	
School		Multnomah	
Street			
15840 SE Taylor St			
City	State	Zip	
Portland	OR	97233	
Latitude		Longitude	
45.51539		122.49973	
Tracking Code		Inspection Date	
RVS in 2006		7/18/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	2.8	-1	-0.5	0	0	-0.4	0	0	0.9
Secondary	PC1	2.6	0	-0.5	0	0	-0.4	0	0	1.7
Tertiary		0	0	0	0	0	0	0	0	0

Harold Oliver Intermediate Center

Final RVS Score

Final Type

Final Score

RM1

0.9

FEMA-154 Collapse Potential

High (>10%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Harold Oliver Intermediate Center

Mult_sch150A

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
390	1969	1969	1960
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
83458	1	No	Yes

Plan Irregularities	Vertical Irregularities
Reentrant Corners: Other	Steps in Elevation View: 2 to 3 Changes
Reentrant Corners: Other (Adjacent Build/Entity)	Steps in Elevation View: 2 to 3 Changes (Adjacent Building/Entity)
None	None

Falling Hazards	Poor Conditions
Unreinforced Chimneys	None
None	None
None	None



W Plan Irregularity Primary



W Elevation View



N Elevation View



NE Vertical Irregularity Primary



NE Secondary Structural Type
PC1 PART



E Secondary Structural Type



E Field Verified Year Built
AND INSIDE BRICK



NE Elevation View

Harold Oliver Intermediate Center

Centennial SD 28J

Mult_sch150B

Building Type		County	
School		Multnomah	
Street			
15840 SE Taylor St			
City	State	Zip	
Portland	OR	97233	
Latitude		Longitude	
45.51579		122.50028	
Tracking Code		Inspection Date	
RVS in 2006		7/18/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C2	2.8	-1	-0.5	0	0	-0.4	0	0	0.9
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Harold Oliver Intermediate Center

Final RVS Score

Final Type

Final Score

C2

0.9

FEMA-154 Collapse Potential

High (>10%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Harold Oliver Intermediate Center

Mult_sch150B

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
390		1969	1970
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
83458	1	No	Yes

Plan Irregularities	Vertical Irregularities
Reentrant Corners: Other (Adjacent Build/Entity)	Steps in Elevation View: 2 to 3 Changes
None	Steps in Elevation View: Single Change (Adjacent Building/Entity)
None	None

Falling Hazards	Poor Conditions
None	None
None	None
None	None



N Elevation View



NE General Site



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries