

Building Type	County	
School	Multnomah	
Street		
116 N Page		
City	State	Zip
Portland	OR	97227
Latitude	Longitude	
45.53925	122.66744	
Tracking Code	Inspection Date	
RVS in 2006	7/10/2006	



Seismicity Zone: High

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	PC1	2.6	0	-0.5	0	0	-0.4	0	0	1.7
Secondary										
Tertiary										0

Trillium

## Final RVS Score

Final Type	Final Score
PC1	1.7

## FEMA-154 Collapse Potential

Moderate (&gt;1%)



Enrollment 223	Year Built (Field Verified) 1980	Year Built (Alt. Source) 1980	Est. Decade Built 1980
Total Area (square ft) 10000	Number of Stories 2	Basement No	Pounding Potential Yes
Plan Irregularities Reentrant Corners: L Shaped None None		Vertical Irregularities None None None	
Falling Hazards Other: General None None		Poor Conditions None None None	
 NW Elevation View		 N Building Name	
 S Falling Hazard		 SW Primary Structural Type	

