

# Skyline Elementary School

Portland SD 1J

Mult\_sch158A

Building Type	County	
School	Multnomah	
Street		
11536 NW Skyline Blvd		
City	State	Zip
Portland	OR	97231
Latitude	Longitude	
45.60752	122.85655	
Tracking Code	Inspection Date	
Structural Engineering Report		
9/15/2006		



Seismicity Zone: High

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	-2	-0.5	-1	0	-0.4	0	0	-0.1
Secondary										
Tertiary										0

Skyline Elementary School

### Final RVS Score

Final Type	Final Score
W2	-0.1

### FEMA-154 Collapse Potential

Very High (100%)

No  
Planview  
Available



OregonGeology

# Skyline Elementary School

Mult\_sch158A

Enrollment 201	Year Built (Field Verified) 1939	Year Built (Alt. Source) 1939	Est. Decade Built
Total Area (square ft) 37245	Number of Stories 2	Basement	Pounding Potential No
Plan Irregularities		Vertical Irregularities	
Falling Hazards		Poor Conditions	