

David Douglas High - South

David Douglas SD 40

Mult_sch165A

Building Type	County	
School	Multnomah	
Street		
1500 SE 130th Ave		
City	State	Zip
Portland	OR	97233
Latitude	Longitude	
45.51255	122.52869	
Tracking Code	Inspection Date	
RVS in 2006	7/12/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C2	2.8	-1	-0.5	0	0	-0.4	0	0	0.9
Secondary	RM1	2.8	-1	-0.5	0	0	-0.4	0	0	0.9
Tertiary		0	0	0	0	0	0	0	0	0

David Douglas High - South

Final RVS Score

Final Type	Final Score
C2	0.9

FEMA-154 Collapse Potential

High (>10%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

David Douglas High - South

Mult_sch165A

Enrollment 2768	Year Built (Field Verified) 1953	Year Built (Alt. Source) 1953	Est. Decade Built 1950
Total Area (square ft)	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities		Vertical Irregularities	
Reentrant Corners: Other		Steps in Elevation View: Very Irregular Changes	
Large Diaphragm or Central Opening		None	
None		None	
Falling Hazards		Poor Conditions	
Other: General		None	
None		None	
None		None	



S Secondary Structural Type



S Falling Hazard



SW Elevation View



W Elevation View



NW Elevation View



N Plan Irregularity Primary



NE Plan Irregularity Primary




OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

David Douglas High - South Horner Performing Arts C Mult_sch165B

David Douglas SD 40

Building Type	County
School	Multnomah
Street	
1400 SE 130th Ave	
City	State Zip
Portland	OR 97233
Latitude	Longitude
45.51408	122.52782
Tracking Code	Inspection Date
RVS in 2006	7/12/2006



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	S3	3.2	0	-0.5	0	0	-0.4	0	0	2.3
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

David Douglas High - South Horner Performing Arts Center

Final RVS Score

Final Type	Final Score
S3	2.3

FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Enrollment 2768	Year Built (Field Verified) 1979	Year Built (Alt. Source) 1953	Est. Decade Built 1970
Total Area (square ft)	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities Reentrant Corners: Other None None		Vertical Irregularities Steps in Elevation View: Very Irregular Changes None None	
Falling Hazards None None None		Poor Conditions None None None	
 NW Other		 W Vertical Irregularity Primary	 NE Vertical Irregularity Primary



David Douglas High - South Childrens Services And

Mult_sch165C

David Douglas SD 40

Building Type	County
School	Multnomah
Street	
1400 SE 135th Ave	
City	State Zip
Portland	OR 97233
Latitude	Longitude
45.51318	122.52421
Tracking Code	Inspection Date
RVS in 2006	7/12/2006



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	-2	-0.5	0	0	-0.4	0	0	0.9
Secondary	C2	2.8	-1	-0.5	0	0	-0.4	0	0	0.9
Tertiary		0	0	0	0	0	0	0	0	0

David Douglas High - South Childrens Services And Classrooms

Final RVS Score

Final Type	Final Score
W2	0.9

FEMA-154 Collapse Potential

High (>10%)



OregonGeology

David Douglas High - South Childrens Services And Cla

Mult_sch165C

Enrollment 2768	Year Built (Field Verified) 1949	Year Built (Alt. Source) 1953	Est. Decade Built 1940
Total Area (square ft)	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities Reentrant Corners: L Shaped None None		Vertical Irregularities Steps in Elevation View: 2 to 3 Changes None None	
Falling Hazards Unreinforced Chimneys Other: General None		Poor Conditions Other None None	
			
NE Vertical Irregularity Primary	SE Vertical Irregularity Primary	SE Falling Hazard	
			
SE Plan Irregularity Primary	S Secondary Structural Type	SE Primary Structural Type	
			
SE Primary Structural Type	SE Primary Structural Type		



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries