

Building Type	County	
School	Multnomah	
Street		
4300 Sw 47th Dr		
City	State	Zip
Portland	OR	97221
Latitude	Longitude	
45.49176	122.72432	
Tracking Code	Inspection Date	
Already Retrofitted	9/15/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	-2	-0.5	0	0	-0.4	0	0	0.9
Secondary										
Tertiary										0

Bridlemile Elementary School

Final RVS Score

Final Type

Final Score

W2

0.9

FEMA-154 Collapse Potential

Moderate (>1%)

No Planview Available



Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
459		1958	
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
59037	1	No	No

Plan Irregularities	Vertical Irregularities

Falling Hazards	Poor Conditions