

Building Type School	County Multnomah	
Street 10625 SW 35th		
City Portland	State OR	Zip 97219
Latitude 45.4487	Longitude 122.71469	
Tracking Code Structural Engineering Report	Inspection Date 9/15/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C1	2.5	-1.5	-0.5	0	0	-0.4	0	0	0.1
Secondary										
Tertiary										0

Jackson Middle School

Final RVS Score

Final Type	Final Score
C1	0.1

FEMA-154 Collapse Potential

High (>10%)

No
Planview
Available



Oregon Geology

Jackson Middle School

Mult_sch30A

Enrollment 694	Year Built (Field Verified) 1966	Year Built (Alt. Source) 1966	Est. Decade Built
Total Area (square ft) 247779	Number of Stories 2	Basement	Pounding Potential No
Plan Irregularities		Vertical Irregularities	
Falling Hazards		Poor Conditions	