

Capitol Hill Elementary School

Portland SD 1J

Mult_sch43A

Building Type	County	
School	Multnomah	
Street		
8401 Sw 17th Ave		
City	State	Zip
Portland	OR	97219
Latitude	Longitude	
45.46407	122.69563	
Tracking Code	Inspection Date	
Already Retrofitted	9/15/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	-2	-0.5	-1	0	-0.4	0	0	-0.1
Secondary										
Tertiary										0

Capitol Hill Elementary School

Final RVS Score

Final Type	Final Score
W2	-0.1

FEMA-154 Collapse Potential

Moderate (>1%)

No
Planview
Available



OregonGeology

Capitol Hill Elementary School

Mult_sch43A

Enrollment 335	Year Built (Field Verified) 1917	Year Built (Alt. Source) 1917	Est. Decade Built
Total Area (square ft) 46379	Number of Stories 2	Basement	Pounding Potential No
Plan Irregularities		Vertical Irregularities	
Falling Hazards		Poor Conditions	