

Building Type	County	
School	Multnomah	
Street		
6941 N Central St		
City	State	Zip
Portland	OR	97203
Latitude	Longitude	
45.58932	122.73825	
Tracking Code	Inspection Date	
Structural Engineering Report	9/15/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	URM	1.8	-1	-0.5	-0.2	0	0	-0.6	0	-0.5
Secondary										
Tertiary										0

Spanish-English International School

Final RVS Score

Final Type	Final Score
URM	-0.5

FEMA-154 Collapse Potential

Very High (100%)

No
Planview
Available



Spanish-English International School

Mult_sch50A

Enrollment 212	Year Built (Field Verified) 1921	Year Built (Alt. Source) 1921	Est. Decade Built
Total Area (square ft) 267570	Number of Stories 2	Basement No	Pounding Potential No
Plan Irregularities		Vertical Irregularities	
Falling Hazards		Poor Conditions	