

Portland SD 1J

Building Type	County	
School	Multnomah	
Street		
6941 N Central St		
City	State	Zip
Portland	OR	97203
Latitude	Longitude	
45.58932	122.73825	
Tracking Code	Inspection Date	
Structural Engineering Report	9/15/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	URM	1.8	-1	-0.5	-0.2	0	0	-0.6	0	-0.5
Secondary										
Tertiary										0

Pursuit of Wellness Education at Roosevelt Campus

Final RVS Score

Final Type

Final Score

URM

-0.5

FEMA-154 Collapse Potential

Very High (100%)

No Planview Available



Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
284		1921	
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
267570	2	No	No

Plan Irregularities	Vertical Irregularities

Falling Hazards	Poor Conditions