

Roosevelt High - SEIS

Mult_sch52A

Portland SD 1J

Building Type		County	
School		Multnomah	
Street			
6941 N Central St			
City	State	Zip	
Portland	OR	97203	
Latitude	Longitude		
45.58932	122.73825		
Tracking Code	Inspection Date		
Already Retrofitted	9/15/2006		



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	URM	1.8	-1	-0.5	-0.2	0	0	-0.6	0	-0.5
Secondary										
Tertiary										0

Roosevelt High - SEIS

Final RVS Score

Final Type

Final Score

URM

-0.5

FEMA-154 Collapse Potential

Moderate (>1%)

**No
Planview
Available**



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
92		1921	
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
267570	2	No	No

Plan Irregularities	Vertical Irregularities

Falling Hazards	Poor Conditions