

Building Type	County	
School	Multnomah	
Street		
5210 N Kerby Ave		
City	State	Zip
Portland	OR	97217
Latitude	Longitude	
45.56046	122.67211	
Tracking Code	Inspection Date	
Already Retrofitted	9/15/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card										
	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	URM	1.8	-1	-0.5	-0.2	0	-0.4	0	0	-0.3
Secondary										
Tertiary										0

School of Pride

Final RVS Score	
Final Type	Final Score
URM	-0.3
FEMA-154 Collapse Potential	
Moderate (>1%)	

No  
Planview  
Available



# School of Pride

Mult\_sch53A

Enrollment 299	Year Built (Field Verified) 1909	Year Built (Alt. Source) 1909	Est. Decade Built
Total Area (square ft) 360911	Number of Stories 4	Basement	Pounding Potential No
Plan Irregularities		Vertical Irregularities	
Falling Hazards		Poor Conditions	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries