

Stephenson Elementary School

Portland SD 1J

Mult_sch55A

Building Type	County	
School	Multnomah	
Street		
2627 Sw Stephenson St		
City	State	Zip
Portland	OR	97219
Latitude	Longitude	
45.44086	122.70395	
Tracking Code	Inspection Date	
Already Retrofitted	9/15/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	-2	-0.5	0	0	-0.4	0	0	0.9
Secondary										
Tertiary										0

Stephenson Elementary School

Final RVS Score

Final Type	Final Score
W2	0.9

FEMA-154 Collapse Potential

Moderate (>1%)

No
Planview
Available



OregonGeology

Stephenson Elementary School

Mult_sch55A

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
325		1965	
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
42958	1	No	No

Plan Irregularities	Vertical Irregularities

Falling Hazards	Poor Conditions



S General Site



S General Site



S General Site



S General Site



S General Site



S General Site