

Sacramento Elementary School

Parkrose SD 3

Mult_sch60A

Building Type	County
School	Multnomah
Street	
11400 NE Sacramento	
City	State Zip
Portland	OR 97220
Latitude	Longitude
45.53903	122.54471
Tracking Code	Inspection Date
RVS in 2006	6/28/2006



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C2	2.8	-1	-0.5	0	0	-0.4	0	0	0.9
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Sacramento Elementary School

Final RVS Score

Final Type	Final Score
C2	0.9

FEMA-154 Collapse Potential

High (>10%)



OregonGeology

Sacramento Elementary School

Mult_sch60A

Enrollment 423	Year Built (Field Verified) 1983	Year Built (Alt. Source) 1983	Est. Decade Built 1960
Total Area (square ft) 49528	Number of Stories 2	Basement No	Pounding Potential Yes
Plan Irregularities Reentrant Corners: Other None None		Vertical Irregularities Steps in Elevation View: Single Change None None	
Falling Hazards Unreinforced Chimneys None None		Poor Conditions None None None	
 E General Site		 NE Vertical Irregularity Primary	
 NE Falling Hazard		 W Pounding Potential	
 SW Plan Irregularity Primary			



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Sacramento Elementary School

Mult_sch60B

Parkrose SD 3

Building Type	County	
School	Multnomah	
Street		
11400 NE Sacramento		
City	State	Zip
Portland	OR	97220
Latitude	Longitude	
45.53896	122.54565	
Tracking Code	Inspection Date	
RVS in 2006	6/28/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C2	2.8	0	-0.5	0	0	-0.4	0	0	1.9
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Sacramento Elementary School

Final RVS Score

Final Type	Final Score
C2	1.9

FEMA-154 Collapse Potential

Moderate (>1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Sacramento Elementary School

Mult_sch60B

Enrollment 423	Year Built (Field Verified) 1983	Year Built (Alt. Source) 1983	Est. Decade Built 1960
Total Area (square ft) 49528	Number of Stories 1	Basement No	Pounding Potential Yes
Plan Irregularities Reentrant Corners: Other None None		Vertical Irregularities None None None	
Falling Hazards None None None		Poor Conditions None None None	
			
N Pounding Potential	SE Elevation View	S Primary Structural Type	
			
W Elevation View	SW Falling Hazard		



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries