

Benson Polytechnic High School

Portland SD 1J

Mult_sch63A

Building Type		County	
School		Multnomah	
Street			
546 Ne 12th Ave			
City	State	Zip	
Portland	OR	97232	
Latitude		Longitude	
45.52723		122.65216	
Tracking Code		Inspection Date	
Already Retrofitted		9/15/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	URM	1.8	-1	-0.5	-0.2	0	0	-0.6	0	-0.5
Secondary										
Tertiary										0

Benson Polytechnic High School

Final RVS Score

Final Type

Final Score

URM

-0.5

FEMA-154 Collapse Potential

Moderate (>1%)

**No
Planview
Available**



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
1452		1916	
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
441219	2	No	No

Plan Irregularities	Vertical Irregularities

Falling Hazards	Poor Conditions