

Chief Joseph Elementary School

Portland SD 1J

Mult_sch65A

Building Type	County	
School	Multnomah	
Street		
2409 N Saratoga St		
City	State	Zip
Portland	OR	97217
Latitude	Longitude	
45.57282	122.69137	
Tracking Code	Inspection Date	
Structural Engineering Report		
9/15/2006		



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	-2	-0.5	0	0	-0.4	0	0	0.9
Secondary										
Tertiary										0

Chief Joseph Elementary School

Final RVS Score

Final Type	Final Score
W2	0.9

FEMA-154 Collapse Potential

High (>10%)

No
Planview
Available



OregonGeology

Chief Joseph Elementary School

Mult_sch65A

Enrollment 393	Year Built (Field Verified) 1949	Year Built (Alt. Source) 1949	Est. Decade Built
Total Area (square ft) 46204	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities		Vertical Irregularities	
Falling Hazards		Poor Conditions	