

Building Type	County
School	Multnomah
Street	
2700 Ne 127th Ave	
City	State Zip
Portland	OR 97230
Latitude	Longitude
45.54133	122.53119
Tracking Code	Inspection Date
RVS in 2006	6/28/2006



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	2.8	-1	-0.5	0	0	-0.4	0	0	0.9
Secondary	C2	2.8	-1	-0.5	0	0	-0.4	0	0	0.9
Tertiary		0	0	0	0	0	0	0	0	0

Russell Academy

Final RVS Score

Final Type	Final Score
RM1	0.9

FEMA-154 Collapse Potential

High (>10%)



Russell Academy

Mult_sch67A

Enrollment 396	Year Built (Field Verified) 1961	Year Built (Alt. Source) 1961	Est. Decade Built 1960		
Total Area (square ft) 43973	Number of Stories 1	Basement	Pounding Potential Yes		
Plan Irregularities		Vertical Irregularities			
Reentrant Corners: L Shaped		Steps in Elevation View: Single Change			
Torsion: Eccentric Stiffness		None			
None		None			
Falling Hazards		Poor Conditions			
Unreinforced Chimneys		None			
Other: Ornamental Hazard Over Exit		None			
None		None			
	SW Elevation View		S Falling Hazard		SE Elevation View
	SE Elevation View		E Pounding Potential		E Plan Irregularity Primary
	W Elevation View				



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Building Type	County
School	Multnomah
Street	
2700 Ne 127th Ave	
City	State Zip
Portland	OR 97230
Latitude	Longitude
45.54181	122.53118
Tracking Code	Inspection Date
RVS in 2006	6/28/2006



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	2.8	0	0	0	0	-0.4	0	0	2.4
Secondary	C2	2.8	0	0	0	0	-0.4	0	0	2.4
Tertiary		0	0	0	0	0	0	0	0	0

Russell Academy

Final RVS Score

Final Type	Final Score
RM1	2.4

FEMA-154 Collapse Potential

Low (<1%)



Enrollment 396	Year Built (Field Verified) 1961	Year Built (Alt. Source) 1961	Est. Decade Built 1960
Total Area (square ft) 43973	Number of Stories 1	Basement	Pounding Potential Yes
Plan Irregularities None None None		Vertical Irregularities None None None	
Falling Hazards Other: General None None		Poor Conditions None None None	
 SE Primary Structural Type		 E Elevation View	
 S Primary Structural Type		 NW Elevation View	
 W Pounding Potential			

