

# Abernethy Elementary School

Mult\_sch69A

Portland SD 1J

Building Type		County	
School		Multnomah	
Street			
2421 Se Orange Ave			
City	State	Zip	
Portland	OR	97214	
Latitude		Longitude	
45.50574		122.65147	
Tracking Code		Inspection Date	
Already Retrofitted		9/15/2006	



Seismicity Zone: High

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C2	2.8	-1	-0.5	-1	0	-0.4	0	0	-0.1
Secondary										
Tertiary										0

Abernethy Elementary School

## Final RVS Score

Final Type

Final Score

C2

-0.1

FEMA-154 Collapse Potential

Moderate (>1%)

**No  
Planview  
Available**



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
366		1924	
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
50358	2	No	No

Plan Irregularities	Vertical Irregularities

Falling Hazards	Poor Conditions