

Building Type	County	
School	Multnomah	
Street		
3039 Ne Portland Blvd		
City	State	Zip
Portland	OR	97211
Latitude	Longitude	
45.57099	122.63512	
Tracking Code	Inspection Date	
Structural Engineering Report		
9/15/2006		



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	-2	-0.5	0	0	-0.4	0	0	0.9
Secondary										
Tertiary										0

Faubion Elementary School

Final RVS Score

Final Type	Final Score
W2	0.9

FEMA-154 Collapse Potential

High (>10%)

No
Planview
Available



OregonGeology

Faubion Elementary School

Mult_sch75A

Enrollment 309	Year Built (Field Verified) 1950	Year Built (Alt. Source) 1950	Est. Decade Built
Total Area (square ft) 57846	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities		Vertical Irregularities	
Falling Hazards		Poor Conditions	