

Building Type School	County Multnomah	
Street 1915 Ne 33rd		
City Portland	State OR	Zip 97212
Latitude 45.53687	Longitude 122.63134	
Tracking Code Already Retrofitted	Inspection Date 9/15/2006	



Seismicity Zone: High

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	URM	1.8	-1	-0.5	-0.2	0	0	-0.6	0	-0.5
Secondary										
Tertiary										0

## Fernwood Middle School

## Final RVS Score

Final Type	Final Score
URM	-0.5

## FEMA-154 Collapse Potential

Moderate (&gt;1%)

No  
Planview  
Available



Oregon Geology

# Fernwood Middle School

Mult\_sch76A

Enrollment 466	Year Built (Field Verified) 1911	Year Built (Alt. Source) 1911	Est. Decade Built
Total Area (square ft) 74963	Number of Stories 3	Basement	Pounding Potential No
Plan Irregularities		Vertical Irregularities	
Falling Hazards		Poor Conditions	