

Gray Middle School

Portland SD 1J

Mult_sch79A

Building Type		County	
School		Multnomah	
Street			
5505 Sw 23rd Ave			
City	State	Zip	
Portland	OR	97239	
Latitude	Longitude		
45.48246	122.70121		
Tracking Code	Inspection Date		
Structural Engineering Report	9/15/2006		



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	-2	-0.5	0	0	-0.4	0	0	0.9
Secondary										
Tertiary										0

Gray Middle School

Final RVS Score

Final Type

Final Score

W2

0.9

FEMA-154 Collapse Potential

High (>10%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
496		1951	
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
60624	2	No	No

Plan Irregularities

Vertical Irregularities

Falling Hazards

Poor Conditions



S General Site



S General Site



S General Site



S General Site



S General Site



S General Site